

2021 Annual Drinking Water Quality Report

Rockbridge County Public Service Authority

INTRODUCTION

This Annual Drinking Water Quality Report for calendar year 2021 is designed to provide you with valuable information about your drinking water quality. The Rockbridge County Public Service Authority is committed to providing you with a safe and dependable supply of drinking water, and we want you to understand the efforts we make to protect your water supply. This system is operated and maintained by the Rockbridge County PSA. The quality of your drinking water meets all State and Federal requirements administered by the Virginia Department of Health (VDH), Office of Drinking Water.

If you have questions about this report, want additional information about any aspect of your drinking water, or want to know how to participate in decisions that may affect the quality of your drinking water, please contact:

Ms. Melissa Alexander, Executive Director, RCPSA at (540) 463-4329

GENERAL INFORMATION

The sources of drinking water (both tap water and bottled water) includes, rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and can pick up substances resulting from the presence of animal activity, including human. Contaminants that may be present in source water include: (1) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; (2) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; (3) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; (4) Organic chemical contaminants, including synthetic and volatile organic chemicals and pharmaceuticals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, sewage treatment plants and septic systems; (5) Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities. To ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Water from surface sources is treated to make it drinkable while groundwater may or may not have any treatment. Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

All drinking water, including bottled drinking water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

SOURCES AND TREATMENT OF YOUR DRINKING WATER

Your drinking water is groundwater obtained from the City of Buena Vista, wells or both. This system has two distinct but contiguous zones labeled A and B. Zone A's principal source is the wells and its alternate or supplemental source is the City of Buena Vista. Zone B's only source is the City of Buena Vista. Water is supplied to Zone B by a distribution system; to Zone A by a booster pump, a storage tank, and a distribution system.

Chlorination treatment is provided for the well water. The water for Zone B is both chlorinated and fluoridated by the City of Buena Vista.

The design capacity for this section of the Rockbridge County Public Service Authority waterworks is based on the City of Buena Vista capacity.

SOURCE WATER ASSESSMENTS

A source water assessment has been completed by VDH. The assessment determined that our source may be susceptible to contamination because it is located in an area that promotes migration of contaminants from land use activities of concern. You may obtain more specific information by contacting the water system representative listed above.

QUALITY OF YOUR DRINKING WATER

Your drinking water is routinely monitored according to Federal and State Regulations for a variety of contaminants. The tables that follow show the results of our monitoring for the period of January 1st through December 31st, 2021.

DEFINITIONS

In the table and elsewhere in this report you will find many terms and abbreviations with which you might not be familiar. The following definitions are provided to help you better understand these terms:

Non-detects (ND) - lab analysis indicates that the contaminant is not present

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) or Nanograms per liter (nanograms/l) - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Nephelometric Turbidity Unit (NTU) - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level, or MCL - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal, or MCLG - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Variances and exemptions - state or EPA permission not to meet an MCL or a treatment technique under certain conditions

Lead Contaminants

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Fluoride Contaminants

Some people who drink water containing fluoride in excess of the MCL over many years could get bone disease, including pain and tenderness of the bones. Fluoride in drinking water at half the MCL or more may cause mottling of children's teeth, usually in children less than nine years old. Mottling, also known as dental fluorosis, may include brow staining and/or pitting of the teeth, and occurs only in developing teeth before they erupt from the gums.

Water Quality Results

Microbiological Contaminants – Information obtained from City of Buena Vista						
Contaminant / Unit of Measurement	MCLG	MCL	Level Found / Range	Violation	Date of Sample	Typical Source of Contamination
Turbidity NTU	NA	TT=0.3 NTU	MAX: 1.06 NTU Range: 0.010 to 1.06 NTU All monthly samples were < 0.3 NTU 97 % of the time	No	Daily 2021	Soil runoff
		Lowest monthly percent meeting ≤0.3 NTU – 95 %				
		TT = 1 NTU maximum		1.0 NTU		
Inorganic Contaminants						
Contaminant / Unit of Measurement	MCLG	MCL	Level Found / Range	Violation	Date of Sample	Typical Source of Contamination
Nitrate ppm	10	10	Range: ND to 0.85	No	September 2021	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Sodium mg/l	-	-	Range: 0.1 to 4.77	No	June 2020, September 2021	Erosion of natural deposits; de-icing salt runoff; water softeners
Fluoride ppm	4	4	Range: 0.2 to 1.5	No	Monthly 2021	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Barium ppm	2	2	Range: 0.010 to 0.014	No	June 2020, September 2021	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Radiological Contaminants						
Contaminant / Unit of Measurement	MCLG	MCL	Level Found / Range	Violation	Date of Sample	Typical Source of Contamination
Combined Radium pCi/L	0	5	Range: 0.5 to 1.6	No	October 2016	Erosion of natural deposits
Alpha emitters pCi/L	0	15	Range: 0.3 to 0.8	No	October 2016	Erosion of natural deposits
Gross Beta pCi/L	0	50	Range: 1.2 to 4.7	No	October 2016	Decay of natural and man-made deposits
Disinfection By-Products						
Contaminant/Unit of Measurement	MCLG	MCL	Level Found	Violation	Date of Sample	Typical Source of Contamination
TTHM's (Total Trihalomethanes) ppb	NA	80	4.4	No	August 2020	By-product of drinking water chlorination
(HAA5) Haloacetic acids ppb	NA	60	1.2	No	August 2020	By-product of drinking water chlorination
Lead & Copper						
Contaminant / Unit of Measurement	MCLG	MCL	Level Found / Range	Exceedance	Date of Sample	Typical Source of Contamination
Copper ppm	1.3	AL=1.3	0.063 (90 th percentile) None of the five samples collected exceeded the AL.	No	September 2019	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Lead ppb	0	AL=15	2 (90 th percentile) None of the five samples collected exceeded the AL.	No	September 2019	Corrosion of household plumbing systems; Erosion of natural deposits
Disinfectant Residual						
Disinfectant/Unit of Measurement	MCLG	MCL	Level Found / Range	Violation	Date of Sample	Typical Source of Contamination
Chlorine mg/L	4	4	Range: 0.56 to 1.14	No	Monthly	By-product of drinking water chlorination

The results in the table are from testing done in 2016, 2019, 2020 and 2021. The state allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though accurate, is more than one year old.

INFORMATION ABOUT FLUORIDE

This is an alert about your drinking water and a cosmetic dental problem that might affect children under nine years of age. At low levels, fluoride can help prevent cavities, but children drinking water containing more than 2 milligrams per liter (mg/L) of fluoride may develop cosmetic discoloration of their permanent teeth (dental fluorosis). The drinking water provided by Long Hollow has a variable fluoride concentration of non detect to 2.8 mg/L. Dental fluorosis, in its moderate or severe forms, may result in a brown staining and/or pitting of the permanent teeth. This problem occurs only in developing teeth, before they erupt from the gums. Children under nine should be provided with alternative sources of drinking water or water that has been treated to remove the excess fluoride to avoid the possibility of staining and pitting of their permanent teeth. You may also want to contact your dentist about proper use by young children of fluoride containing products by young children. Older children and adults may safely drink the water. Drinking water containing more than 4 mg/L of fluoride (the U.S. Environmental Protection Agency's drinking water standard) can increase your risk of developing bone disease. Your drinking water does not contain more than 4 mg/L of fluoride, but we are required to notify you when we discover that the fluoride levels in your drinking water exceed 2 mg/L because of this cosmetic dental problem. For more information, please call Rockbridge County PSA at the previously listed phone number. Some home water treatment units are also available to remove fluoride from drinking water. To learn more about available home water treatment units, you may call NSF International at 1-877-867-3435 or email info@nsf.org."

We monitor frequently for various contaminants in the water supply to meet all regulatory requirements. The table lists only those contaminants that had some level of detection. Many other contaminants have been analyzed but were not present or were below the detection limits of the lab equipment.

Maximum Contaminant Levels (MCLs) are set at very stringent levels by the U.S. Environmental Protection Agency. In developing the standards, EPA assumes that the average adult drinks 2 liters of water each day throughout a 70-year life span. EPA generally sets MCLs at levels that will result in no adverse health effects for some contaminants or a one-in-ten-thousand to one-in-a-million chance of having the described health effect for other contaminants.

VIOLATION INFORMATION

We did not have any violations during the year 2021.

Rockbridge County Public Service Authority
150 South Main St.
Lexington, VA 24450

The waterworks owners prepared this Drinking Water Quality Report with the assistance and approval of the Virginia Department of Health (VDH).

Signature: _____

Date: _____